



GRAFTON
Massachusetts

Natalia Alward <alwardn@graffon-ma.gov>

Re: 8 Pine Street

1 message

Michael Killeen <killeenm@graffon-ma.gov>
To: planningdept@graffon-ma.gov

Tue, Mar 23, 2021 at 1:56 PM

To whom it may concern,

Regarding the plan for Village at Grafton Woods, the fire department is concerned with the following issues:

- There is no indication of where the Fire Department Connection, or standpipe locations will be in relation to the fire hydrants
- A fire hydrant needs to be located every 500 feet
- What weight will the reinforced turf support, as it must support the weight of the fire department's apparatus
- The reinforced turf path around the residential building must be maintained in the winter to be free and clear of snow, and in the summer to be clear of tree branches and shrubbery

Please feel free to reach out with any questions or concerns. Thank you.

Respectfully,

Michael Killeen

Fire Prevention Officer

Grafton Fire Department